










Linseed Oil Soaked Rags, UL Demonstration (12/27/2018)

		
Test Start (7:00:00 AM)	Lid propped ~2 in. open, first signs of smoke (1:18:16 PM)	Smoke development increases (1:31:14 PM)
		
Propped ~6 in. open to increase ventilation (2:01:00 PM)	Ignition (2:55:35 PM)	Flames coming out from the garbage bin (2:56:00 PM)
		
Significant deformation of garbage bin (2:56:54 PM)	Further deformation (2:57:16 PM)	Test terminated, significant fire (2:58:00 PM)